



## Eyewash Weekly Inspection Form

An emergency eyewash fixture is provided to flush tepid water to the eye, diluting any hazardous materials that may have come into contact with the eyes.

### General Requirements:

Initial and date in the corresponding box verifying the eyewash station is checked weekly for the following:

- The pathway to the eyewash station is clear of obstructions
- The nozzle dust caps/covers are in place and operating properly
- To test the eyewash station, flush water until clear water flows continually through eyewash head without any leaks, rust, dirt, ect. for approximately 5 seconds. (If problems are evident, call Environmental Health and Safety at 3-4094)

Year_____	Week 1	Week 2	Week 3	Week 4	Comments:
JANUARY					
FEBRUARY					
MARCH					
APRIL					
MAY					
JUNE					
JULY					
AUGUST					
SEPTEMBER					
OCTOBER					
NOVEMBER					
DECEMBER					